

10-31-92

12.3.42

PERMITTEE NAME/ADDRESS:

Name: Holnam, Inc.

Address: 5400 W. Marginal Way
Seattle, WA 98106

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

WA-0002232

PERMIT NUMBER

001

DISCHARGE NUMBER

FORM APPROVED

OMB No.2040-0004

Discharge Location

Lat 47° 33' 30" N

Long 122° 20' 68" W

NO DISCHARGE

Facility: Same As Above

Location: Same As Above

MONITORING PERIOD

FROM 97/10/01 TO 97/10/31

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) (46-53)	Quantity or (54-61)	Loading	(4 Card Only) (38-45)	Quality or (46-53)	Concentration (54-61)	Unit	NO. EX (62-63)	Frequency of analysis (64-68)	Sample Type (69-70)		
		Average	Maximum	Unit	Minimum	Average	Maximum						
TSS	SAMPLE MEASUREMENT	—	—	—	—	—	39	mg/L	0	1/30	Grab		
	PERMIT REQUIREMENT	—	—	—	—	—	50			1/30	GRAB		
pH	SAMPLE MEASUREMENT	—	—	—	9.65	—	9.65	STD	1	1/30	Grab		
	PERMIT REQUIREMENT	—	—	—	6.0	—	9.0			1/30	GRAB		
OIL & GREASE	SAMPLE MEASUREMENT	—	—	—	—	—	21	mg/L	1	1/30	Gab		
	PERMIT REQUIREMENT	—	—	—	—	—	10			1/30	GRAB		
TURBIDITY OF EFFLUENT	SAMPLE MEASUREMENT	—	—	—	—	26	26	NTU	0	1/30	Grab		
	PERMIT REQUIREMENT	—	—	—	—	109	270			1/30	GRAB		
TURBIDITY OF BACKGROUND	SAMPLE MEASUREMENT	—	—	—	—	—	Not Sampled During Interim	NTU	NA	1/30	Grab		
	PERMIT REQUIREMENT	—	—	—	—	—	REPORT			1/30	GRAB		
DIFFERENCE OVER BACKGROUND TURBIDITY	SAMPLE MEASUREMENT	—	—	—	—	—	Not Calculated During Interim	mg/L	NA	1/30	Gab		
	PERMIT REQUIREMENT	—	—	—	—	—	REPORT			1/30	GRAB		
TOTAL RECOVERABLE COPPER	SAMPLE MEASUREMENT	—	—	—	—	—	0.017	mg/L	0	4/yr	Grab		
	PERMIT REQUIREMENT	—	—	—	—	—	REPORT			4/YR	GRAB		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC, 1001 AND 33 USC, 1319. (PENALTIES UNDER THESE STATUTES MAY INCLUDE FINES UP TO \$10,000 AND OR MAXIMUM IMPRISONMENT								TELEPHONE		DATE	
N.F. Stiren, Plant Manager										(206) 937-8025			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT								AREA CODE NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

TURBIDITY SHALL NOT EXCEED 10 NTU OVER BACKGROUND WHEN BACKGROUND IS 50 NTU OR LESS, AND SHALL NOT EXCEED BACKGROUND BY MORE THAN 20% WHEN BACKGROUND IS GREATER THAN 50 NTU.

USEPA SF



1185523